



A P P R O V A L S ®

Certificate of Suitability

* Addendum *

Certificate No.: SAA181946

Date of Issue: 24 July 2018

Class Description: Non-Declared

Product Description: PV Grid-interactive Inverter

Additional Models

Description

iMars BG40KTR

Input: 1100Vdc Max, MPPT range 570-950Vdc, Max 74A, Isc 81A
Output: 3~/N/PE 230/400V~ 50Hz, Max 63.5A, 40kVA

iMars BG50KTR

Input: 1100Vdc Max, MPPT range 570-950Vdc, Max 90A, Isc 99A
Output: 3~/N/PE 230/400V~ 50Hz, Max 72.5A, 50kVA

iMars BG60KTR

Input: 1100Vdc Max, MPPT range 570-950Vdc, Max 120A, Isc 132A
Output: 3~/N/PE 230/400V~ 50Hz, Max 96A, 60kVA

A handwritten signature in black ink, appearing to be 'L. ...', positioned above a horizontal line.

For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd certifies that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au



Issued: 25-07-18 181946/2a
Ratings corrected