



A P P R O V A L S ®

## Certificate of Suitability

### \* Addendum \*

**Certificate No.:** SAA152520

**Date of Issue:** 15 October 2020

**Regulatory Definition:** Non-Prescribed

**Product Description:** PV Grid-interactive Inverter

**General Modification:**

Hardware version: H.3

Software version: V3.01

Additional Models	Trade Name	Rating/Marking
iMars MG4KTL	invt	Input: 600Vdc Max, Isc PV 18A Output: 230V~ 50Hz 16A 3680VA ta:60°C, IP65, Class I
iMars MG4K6TL	invt	Input: 600Vdc Max, Isc PV 20A Output: 230V~ 50Hz 18.3A 4200VA ta:60°C, IP65, Class I
iMars MG5KTL	invt	Input: 600Vdc Max, Isc PV 22A Output: 230V~ 50Hz 20A 4600VA ta:60°C, IP65, Class I
iMars MG3KTL-2M	invt	Input: 600Vdc Max, Isc PV 2x9A Output: 230V~ 50Hz 14A 3000VA ta:60°C, IP65, Class I
iMars MG4KTL-2M	invt	Input: 600Vdc Max, Isc PV 2x11A Output: 230V~ 50Hz 16A 3680VA ta:60°C, IP65, Class I

*R.A. Hill*


For and on Behalf of  
SAA Approvals Pty Ltd

This certificate is issued by SAA Approvals Pty Ltd in accordance with the SAA Approvals Electrical Product Safety Certification Scheme accredited by JAS-ANZ under AS/NZS ISO/IEC 17065 and RECS accreditation under the Queensland Government legislative requirements. SAA certifies the product nominated in this certificate complies with standard/s listed above in accordance with the schemes herein.

For SAA Contact Details and to verify this Certificate go to:

[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



[www.jas-anz.org/register](http://www.jas-anz.org/register)



Issued: 15-10-20 152520/2a  
Renewed, updated